



STA=112 PS I  
RES = 70 PSI

STA = 115 PS I  
FLOW=1840 G.P.M

✓ Davis Properties, Inc.  
to  
Commissioners of Public Works  
of the City of Greenville, S. C.  
January 10, 1984  
Pt. of Blk. Book 291-1-7.7

NOTE: ALL VALS. OPEN LEFT  
FIRE HYD. TO BE 3-WAY & OPEN LEFT

Material List:

6" D. I. Pipe	-	210'±
2" Galv. Pipe	-	535'±
6" Valves	-	2
2" Valves	-	4
Fire Hydrant	-	1
Valve Boxes	-	6

GILDER CREEK ESTATES PHI  
MAY 1983 SCALE 1"=400'

459

RECORDED JUL 5 1984 at 10:31 A.M.

1325 RV 2