



FLOW = 1450 G.P.M.

STATIC = 95 PSI.  
RES. = 90 PSI.

**NOTE: ALL 6" & 8" VALVES OPEN RIGHT.  
2" VALVES OPEN LEFT  
FIRE HYDRANT TO BE 3-WAY &  
OPEN RIGHT.**

**MATERIAL LIST:**

8" D. I. Pipe	-	890'±
6" D. I. Pipe	-	35'±
2" Galv. Pipe	-	365'±
6" Valves	-	2
2" Valves	-	3
Fire Hydrant	-	1
Valve Boxes	-	5

**PELHAM OAKS SEC 182**

JULY, 1983 SCALE 1"=400'  
REVISED

JUNE, 1984

Woodfield Land Company, A General Partnership  
to  
Commissioners of Public Works  
of the City of Greenville, S. C.  
June 27, 1984  
BLK. BOOK-540-2-1-27 540.2-1-24

RECORDED JUL 17 1984 at 11.34 A.M. 1758

54328-172